

Certificate

SEBS-A.091351/12, V1.0

TÜV NORD Systems GmbH & Co. KG hereby certifies to

**Honeywell International Inc.
Honeywell Field Products**

512 Virginia, Dr.
Fort Washington, PA 19034, USA

that the safety-related

SmartLine ST 800 HART Pressure Transmitter

is capable for safety related applications up to SIL 2, SIL 3 depending on the architecture and meets the requirements listed in the following standard.


IEC 61508: 2010;

**Functional safety of
electrical/electronic/programmable
electronic safety-related systems;
Capable up to SIL 2 for single transmitter use;
Capable up to SIL 3 for multiple transmitter use**

The certification is based on the valid version of report SEBS-A.091351/12TB. This certificate entitles the holder to use the pictured Safety Approved mark.

Expiry date: 2017-12-20

Reference No.: G.SEB.BS.02.006.08.031


Gerhard M. Rieger
Branch Manager

Augsburg, 2012-12-20

